

THE BASICS OF FOUL CONDENSATE STRIPPING

Tom Burgess, P.Eng.
 Senior Manager
 Environmental Technology
 Georgia-Pacific Corporation
 133 Peachtree St. N.E.
 Atlanta, Georgia. 30303

ABSTRACT

Foul condensates from the digesters and evaporators contain reduced sulfur gas and organic compounds, such as methanol (MeOH) and turpentine, which contribute greatly to pulp mill water pollution in the form of Biochemical Oxygen Demand (BOD) and toxicity, and air pollution in the form of Volatile Organic Compounds (VOC), and odor.

For this reason, foul condensates are collected and treated by stripping, using either air or steam, to remove the pollutants. In many cases, the pollutants can be economically used as a fossil fuel substitute.

This paper will cover the condensates that are collected, various stripping methods, types of stripping columns, basic theory, operating problems, the latest operating procedures, and disposal of the stripper off gas (SOG) which contains the pollutants removed.

INTRODUCTION

The Cluster Rules resulting from the Clean Air Act Amendments (CAAA) of 1990, will require the collection and treatment of "Kraft process condensates", better know as foul condensates or combined condensates.

Steam stripping is one of the treatments accepted by the Environmental Protection Agency (EPA). The others are hard piping to biological treatment, reusing the condensates in a process where the vents are collected and incinerated, or any other process that can meet the required removal efficiencies.

TABLE I
Typical Pollutant Loads in Foul Condensates
Bleached Kraft Mill
Based on Unbleached Digester Production

Source	Total Flow		MeOH		Turpentine		TRS	
	kg/tonne	lb/ton	kg/t	lb/t	kg/t	lb/t	kg/t	lb/t
<u>Batch Digester Mill (Softwood)</u>								
Digester accumulator overflow	1,125	2250	4.0	8.0	0.50	1.0	0.20	0.40
Turpentine decanter underflow	250	500	1.5	3.0	0.50	1.0	0.15	0.30
Total Evaporator Condensate	7,000	14000	4.2	8.4	0.25	0.5	1.00	2.00
<u>Continuous Digester Mill (Softwood)</u>								
Turpentine decanter underflow	450	900	2.5	5.0	0.50	1.0	0.12	0.24
Total Evaporator Condensate	8,000	16000	7.5	15.0	0.50	1.0	1.20	2.40

Although the rules allow various methods of determining removal efficiencies, bleached mills will have to collect selected condensates and treat them to destroy 10.2 pounds of methanol (MeOH) per oven dry ton of pulp (ODTP) (5.1 kilograms per oven dry megagram of pulp). Unbleached mills will have to destroy 6.6 pounds per ODTP (3.3 kg/Mg).

Most mills built or upgraded since 1980 have had a condensate stripping system installed as an integral part of the overall mill process. Many older mills have now added a foul condensate stripper to meet the new EPA Cluster Rule.

WHY STRIP FOUL CONDENSATES?

The prime reason for stripping foul condensates is pollution control. Foul condensates can contain 14 to 20 lb. (7 to 10 kg) of BOD, 2 to 4 lb. (1 to 2 kg) of turpentine and 2 to 4 lb. (1 to 2 kg) of TRS per ton (tonne) of pulp (Table I). If these foul condensates are untreated, they cannot be reused in the mill and are therefore sewered, putting a high load of BOD and toxicity into the secondary treatment system and

frequently causing air pollution problems, as the TRS and MeOH is released to the atmosphere by flashing off from open sewers. By collecting these foul condensates and stripping them, most of the pollutants can be removed and burned, reducing the pollution load to the air and to the secondary treatment system.

In most cases, the stripped condensates can be reused in the mill for such purposes as brown stock washing and make-up water in the recaust area. Thus, stripping also has the potential to reduce the total mill water demand. Stripping will also be an integral part of the effluent free mill of the future.

Fortunately, the stripped compounds are easily burned. Heat of combustion values for stripper overheads in the order of 120,000 Kcal/tonne (475,000 BTU/Ton) pulp have been reported (Table II). These stripper overheads can be transported as a gas, or condensed and transported as a liquid and used to replace fossil fuel in lime kilns, boilers and incinerators. In most cases, the net heat released by burning these pollutants is greater than the heat energy required to operate the stripper, and can be used to help economically justify installing the stripping system.

TABLE II
Heat Value of Pollutants

Pollutant	Net Heat of Combustion	
	kgcal/kg	BTU/LB
MeOH	5,037	9,066
Alpha-Pinene	9,547	17,200
H ₂ S	3,647	6,565
CH ₃ SH	6,229	11,212
CH ₃ SCH ₃	7,371	13,268
CH ₃ SSCH ₃	5,638	10,148

WHAT CONDENSATES ARE STRIPPED?

The Cluster Rule requires collection and treatment of the condensates from the digester system, the turpentine recovery system, the evaporator systems, the HVLC (dilute NCG) collection system, and the LVHC (concentrated NCG) system.

Batch Digester Blow Steam Condensate

The condensates from condensed blow steam are rich in methanol and TRS. In order for these pollutants to be collected, however, the blow steam system must function correctly. If the blow steam system is undersized or operated incorrectly, much blow steam is vented with much of the methanol and TRS vented as well. In some mills, fresh water is added to the accumulator to keep the bottom temperature low. This dilution of the blow steam condensate makes collection of these condensates undesirable.

In a modern blow steam condensing system, the direct contact primary condenser is followed by an indirect secondary/tertiary condenser. It has been found that up to 80% of the pollutants can be "segregated" into the 10 - 15% of condensed blow steam that comes from the secondary/tertiary condenser. This concentration of the pollutants in a smaller flow greatly improves the efficiency and economics of stripping.

The Cluster Rule will allow the treatment of only the segregated stream, provided that at least 65% of the methanol in all the blow steam condensates is contained in the segregated stream.

Batch Digester Relief Steam

During the cook, noncondensable gases (NCG) are vented from the digester. The NCG contains considerable amounts of steam, MeOH, and frequently turpentine. This steam must be condensed in

order to collect the NCG. The condensates so formed must be collected and treated. As above, this condensation can be done in two stages, and only the rich or segregated stream collected and treated, providing at least 65% of the methanol in the relief gas is in the segregated stream.

Continuous Digester Flash Steam

During the cook, hot, pressurized liquor is removed from the digester and flashed to atmospheric pressure. The flash steam contains considerable amounts of NCG, MeOH, and frequently turpentine. This steam must be condensed in order to collect the NCG. The condensates so formed must be collected and treated. As above, this condensation can be done in two stages, and only the rich or segregated stream collected and treated, providing at least 65% of the methanol in the flash steam is in the segregated stream.

Turpentine Decanter Underflow

In softwood mills, batch digester relief steam condensates and continuous digester flash steam condensates go to a turpentine recovery system. The underflow from the turpentine decanter is a relatively low flow that is rich in methanol, turpentine and TRS, making this foul condensate a prime candidate for stripping.

Evaporator Condensates

The combined foul condensates from the multiple effect evaporators contain methanol, turpentine and TRS removed from black liquor during evaporation. The evaporators, in effect, act as strippers to remove these pollutants from the black liquor.

It has been found that most of the pollutants (80%+) will collect in the condensates of the effects and condensers following the effects where the weak black liquor is fed. For

example, if weak black liquor is fed to effects 5 and 6 of a six effect evaporator, the pollutants will be found in the condensates from the 6th effect and the surface condenser. The Cluster Rule will allow splitting out such condensates for treatment, thus reducing the amount of evaporator condensate to be treated by about two thirds.

In modern multiple effect evaporators, especially those of the falling film design that have been supplied since 1980, the majority of the pollutants can be collected in 15% or less of the total condensate. This is primarily done by using two-stage condensing with internal condensate segregation. This, as mentioned above, greatly reduces the condensate to be treated, and thus improves the efficiency and economics of stripping.

In general, there will be four condensate streams generated in a modern falling film evaporator. The first is clean steam condensate from the first effect. The second is combined condensates from the middle effects, and these will have methanol in the 100 ppm range. The third stream is contaminated condensates from the lean steam of segregated condensates from the feed effects, and these will have methanol concentrations in the range of 1000 ppm. The final stream is foul condensates from the rich stream of segregated condensates, and the methanol will be in the 5000 ppm range.

The Cluster Rule will allow segregation of condensates, providing that 65% or more of the methanol in all the evaporator condensates is in the segregated stream.

NCG System Condensates

The condensates formed in NCG systems, although small in volume, are very concentrated in methanol and TRS compounds, and contribute to odors in the mill area if drained into open sewers. The Cluster Rules may require collection and treatment of these condensates.

METHODS OF STRIPPING

There are two methods of stripping used in Kraft pulp mills today. One uses air and the other uses steam. Both of these methods can be further subdivided into two types of strippers; stripping for TRS only and stripping for methanol (BOD). TRS is easily stripped, whereas MeOH is more difficult, consequently making the latter systems bigger and more complex. Further, the new Cluster Rules will not accept air stripping, or stripping for TRS only.

Air Stripping for TRS

This is the most basic form of stripping and is generally used to remove TRS from condensates so that they do not create odor problems in the secondary treatment system (Figure 1). In this case, the foul condensates are stripped by air moving countercurrently in a stripper column. About 3 - 5 weight % of air on condensate is required. Higher air ratios may be necessary if the TRS concentration is high, in order that the stripped gases are well below the Lower Explosive Limit (LEL) in the overheads. The two factors which have the greatest effect on air stripper efficiency are temperature and pH (Figure 2). A pH of seven or less and a condensate temperature of 50°C (120°F) or more are required for good stripping efficiency. Disposal of the high volume of warm moist overheads is the major disadvantage of this system.




FIGURE.1 AIR STRIPPER FOR TRS




FIGURE.2 AIR STRIPPER EFFICIENCY

Disposal is usually done by burning in a boiler, kiln or incinerator. The major advantages of this system are its simplicity and low cost.

Air Stripping for BOD

This system is similar to air stripping for TRS, except that much higher quantities of air are required, in the range of 16 - 20 weight % air on condensate. Temperature is also very important and temperatures in excess of 70°C (160°F) are required for good efficiency.

This form of stripping is not practical, and is not practiced.

Steam Stripping for TRS

This system is similar to the air stripper except that two heat exchangers are added to the system (Figure 3). It is necessary to preheat the foul condensate before stripping, otherwise the stripping steam would be condensed by the cold condensate. This preheating is done by heat exchanging with the hot stripped condensate. The second heat exchanger is used to condense the steam out of the stripped TRS gas before it is incinerated. The condensate is returned to




FIGURE.3 STEAM STRIPPER FOR TRS

the top of the stripping column. About 3 - 5 weight % of steam is required on condensate.

As with air stripping, efficiency is pH dependent. Despite the disadvantage of higher capital and operating cost, disposal of the overheads is much simpler. Operating costs can be reduced if some use can be made of the hot water generated in the overhead condenser.

Steam Stripping for BOD

This system is similar to the steam stripper for TRS except that the overhead condenser becomes a reflux condenser and the top of the column becomes a distillation column to concentrate the methanol (Figure 4). The steam requirement increases to 15 - 20 weight % steam on condensate (Figure 5).

These systems have the advantage of high efficiency, producing an overhead that is usable as a fuel. The major disadvantages are high capital and operating costs. The operating costs can be reduced if some use of the heat from the reflux condenser can be found such as preheating boiler feed water, or making clean hot water for a bleach plant.

The reflux tank shown in Figure 4 is optional, and many systems do not have them. Instead, the reflux condenser is positioned above the column, and reflux flows by gravity back to the column.

We have examples of this type of stripping system at our mills in Palatka, FL., and Brunswick, GA.




FIGURE.4 STEAM STRIPPER FOR B.O.D.




FIGURE.5 DISTILLATION EFFICIENCY

TYPES OF COLUMNS

In general, two types of columns are used for stripping; packed columns and valve tray columns.

Packed columns are generally cheaper, especially for small diameter columns. Packing material is either stainless steel pall rings or corrosion resistant plastic saddles. The disadvantages of packed columns are poor turndown ratio and plugging of the packing by fibers carried in the condensate.

Valve tray columns are an advanced form of a bubble cap tray column. They have the advantages of maintaining high efficiency over a wide operating range, a constant pressure drop at varying vapor load rates and self-cleaning of the trays. These advantages normally offset the higher capital cost of the valve tray column.

As a general rule, packed columns are used for TRS strippers and very small BOD strippers, while valve tray columns are used for large BOD strippers. The valve tray column has become the standard under the Cluster Rule.

INTEGRATED COLUMNS

In order to reduce the capital and operating costs of steam type BOD strippers, they are normally integrated into a set of multiple effect evaporators. There are two basic ways to do this.

Fully Integrated (Figure 6)

The stripping column is placed between two effects, usually the #1 and #2. Steam from the #1 effect is run through the stripper and then condensed in the #2 effect. The #2 effect is the reflux condenser, saving this capital cost. The stripping steam is essentially free.




FIGURE 6 FULLY INTEGRATED COLUMN




FIGURE 7 PARTIALLY INTEGRATED COLUMN

However, there is an efficiency loss of about 12% in the evaporators when the column is fully integrated. In a system of this type, for every Kcal or BTU lost by integration, two or more Kcals or BTUs are returned by the heat value from burning the stripped BOD. This type of full integration with respect to the evaporators can be used when a stripper is integrated into an existing mill, and where condensate flows are high compared to the relative size of the evaporators.

Partially Integrated (Figure 7)

In the case of a new mill with reduced foul condensate flows, and where the stripper is part of the initial evaporator design, only partial integration is required. In this case, only part of the evaporator steam flow is used for stripping and the overheads are condensed in either an external preheater or in a dedicated internal section of a subsequent evaporator effect. Such systems have a much better energy return than fully integrated systems. We have an example of this type of stripper at our mill in Leaf River, MS.

COLUMN OPERATION

Stripping columns are generally easy to operate although control schemes for strippers integrated into evaporators can be complex due to their interdependence on evaporator operation. Some problems in column operation are as follows:

Foaming

Liquor in the foul condensate can cause the condensate to foam when air or steam is blown through it. This results in a flooded column where the condensate is carried out the top of the column and steam or air flow is stopped. This problem is handled by measuring the conductivity of the foul condensate. A high conductivity indicates the presence of liquor and the condensate can be dumped before it gets to the column.

This problem will show up as loss of steam flow to the stripper, or high level in the reflux tank.

At worst, the foam will carry through the stripper off gas (SOG) system and into the incineration point, where it may extinguish the flame, or cause other damage.

Unstable Operation

In steam strippers, where steam use is controlled and based on condensate flow, every change in flow upsets the system for several minutes. In a continuous change situation, such as if the condensate feed flow is based on level control of a foul condensate storage tank, the system remains unstable. Therefore, flow changes should be made on a stepwise basis and made as seldom as possible. In the case of an integrated column, the evaporators used should be run as smoothly as possible. If a mill has more than one set of evaporators, the set with the stripper should carry a constant base load while the other set takes up the production rate changes. Unstable operation can also cause problems if the stripper gas is burned in a kiln or an incinerator. Rapid changes in MeOH load can upset the heat balance in the kiln or incinerator.

Unstable operation will result in low stripping efficiency.

Steam Collapse

Once the column is started up, it is full of steam. If enough cold condensate enters the column, it will condense the steam where it enters the column, causing an almost instantaneous high vacuum in the top of the column. The hot condensate in the bottom of the column will boil rapidly, almost exploding. This sudden upward rush will buckle trays, pop them out of their hold down clips, or carry packing out of the column. Such a situation can happen on a start-up, when

there is insufficient hot condensate in the bottom of the column to preheat the foul condensate. Great care must be taken to avoid such situations. Start-ups should be done very slowly.

Loss of trays results in loss of stripping efficiency.

Control of Contaminant Removal

Condensing in the reflux condenser must be controlled to maximise contaminant removal while minimising steam loss. At this point in the process, the system is a very complex, two-phase, multicomponent system, mainly made up of water, methanol, reduced sulfur gases and turpentine, but with several other compounds such as ethanol and acetone in lesser quantities. Good control depends on a combination of pressure and temperature control in the reflux condenser. See **REFLUX CONTROL** below.

Fiber

The foul condensates tend to contain pulp fibers and these fibers can plug packed columns and heat exchangers, especially plate-type heat exchangers. Fortunately, valve tray columns are self-cleaning. The handling of fiber can be done in two ways. The first is to install a good fiber filter before the heat exchanger. The second is to design the system to pass the fiber through, using valve trays and heat exchangers with wide gaps or large diameter tubes.

This problem normally shows up as loss of flow through the heat exchangers, especially plate type heat exchangers.

Plugging of Heat Exchangers

Several mills have experienced a scale build-up on the stripped condensate side of the heat exchanger. The reason for this is still not clear, and the scale is very difficult to

remove. For this reason, the stripped condensate should go through the tube side of the heat exchanger, to facilitate mechanical cleaning. Attempts to chemically remove the scale have been tried, but with mixed success. Chemical cleaning should be done before the tubes get too badly scaled.

This problem usually shows up as loss of flow of the stripper bottoms, or high level in the bottom of the stripper.

Turpentine in Storage Tank

As there is turpentine in the condensates, there is a tendency for the turpentine to decant in the storage tank, and collect on top of the condensates. If this happens, and the storage tank is pulled down, it is possible to send a slug of turpentine to the stripper. The turpentine will easily strip, and the turpentine will go through the SOG system, and cause problems at the incineration point, usually a high temperature trip.

There are several means to avoid the turpentine build up in the storage tank. The first is to send the turpentine decanter underflow, which can be rich in turpentine, directly to the suction of the stripper feed pump. The second method is to make sure there is agitation in the tank, to prevent the turpentine decanting. This can be done by making the incoming condensate lines tangential, recirculating feed condensate back to the tank, or by adding an internal agitator.

Skimming the turpentine can also be done. This can either be done periodically, returning the turpentine to the turpentine recovery system, or by continuously skimming the turpentine into the stripper feed condensate.

REFLUX CONTROL

As mentioned above, good control of the reflux cycle is required to operate the stripper efficiently, both with respect to contaminant removal and heat recovery.

For any given operating pressure, and any desired stripper off gas (SOG) concentration, there is fixed equilibrium temperature. Operating at the proper equilibrium temperature and pressure is necessary in order to control the overhead composition. Further, operating at the proper equilibrium conditions will ensure removal of the turpenes and red oils with the SOG, where they can be burned. If the reflux condensate is allowed to sub cool, the red oils will separate out, and build up in the reflux cycle until they give control problems.

The concentration of methanol in the SOG is a compromise between stripping efficiency and heat recovery. At higher methanol concentrations, heat recovery improves, but stripping efficiency declines. At lower methanol concentrations, stripping efficiency improves, but heat recovery declines. The generally accepted optimum methanol concentration in the overheads is 50% by weight.

In a non integrated stripper, it is possible to control both the pressure and the temperature. Two methods of doing this are shown in Figures 8A and 8B. With an integrated stripper, the evaporator operation will fix the stripping temperature. Thus it is necessary to control the operating pressure based on this temperature.

Temperature control is done by controlling the cooling water flow to the reflux condenser. Pressure control is done by controlling the back pressure on the SOG line.

In the scheme shown in Figure 8A, the temperature of the reflux condensate is

measured rather than the gas, which gives faster response to temperature changes. This assumes that the condensate is not sub-cooled, and is at the equilibrium temperature. The condenser is mounted horizontally in order to minimize sub-cooling of the condensate. This scheme works well at design conditions, but sub-cooling tends to occur at reduced operating rates.



In the scheme shown in figure 8B, gas temperature is measured directly. Vapor from the reflux condenser is bubbled through the condensate in the reflux tank, which ensures that liquid and gas phases are in equilibrium. This gives better control, but at a capital cost penalty.

TRANSPORT AND DISPOSAL OF CONTAMINANTS

Once the contaminants have been stripped out of the condensate and removed from the system, they must be disposed of. The most common way to do this is to carry them in gaseous form and burn them directly in a kiln, boiler or separate incinerator. The system for transport is almost identical to a concentrated or, low volume, high concentration (LVHC) noncondensable gas (NCG) system. See Figure 9.

The major difference with a concentrated NCG system is that the stripper gas system requires makeup steam to ensure purging of the entire system on start-up and to ensure a minimum velocity in the entire line at all times. This is done by measuring the line velocity near the incineration point and adding makeup steam, as necessary, near the pressure control valve at the stripper. The stripper gas system should be operating, with SOG going to incineration, before any foul condensate is sent to the stripper.

The advantages of burning stripper overheads are low cost, simple operation, and recovery of the high fuel value of the contaminants.






Figure 9 Stripper Off Gas system

The major disadvantage is that if this stream is ever vented, it will create a severe odor problem in the local area very quickly.

It is also possible to collect the contaminants as a liquid by use of an extra condenser. This allows for storage of the contaminants

as a liquid, which can be used for fuel or be further refined for recovery of the chemicals.

In the past, the liquid MeOH so collected fell under Resource Conservation and Recovery Act (RCRA) rules classifying it as a hazardous waste, making this form of collection virtually illegal. The Cluster Rule reclassifies this liquid methanol as a "clean fuel", and thus allow it to be collected and stored as a liquid.

In most cases, the SOG will be further rectified to increase the methanol concentration to 85 to 90% by weight.

PROPER OPERATING PROCEDURES

The following procedures have been recently developed to reduce the possibility of steam

collapse, and to eliminate venting of SOG during start-up and shutdown.

The stripper should be started up with steam. Once the stripper is fully heated and all air purged out of the system by cracking open the back pressure control valve, feeding of condensate can begin. At a minimum steam flow of about 20% of design, start with a condensate flow of about 10% of design. After five minutes, increase condensate flow to 20% of design. Continue to increase both condensate and steam flow in 10% increments every five minutes until the full operating rate is achieved.

The slow start-up will prevent damage to the trays due to steam collapse, as well as give the incineration point time to adjust to the changing fuel load from the methanol in the SOG.

As mentioned before, any changes in operating rate should be made in small increments (maximum 10%) and as seldom as possible.

For planned shutdowns, condensate and steam flow should be reduced slowly, until 20% of design is reached. At this point stop

the condensate flow, but leave the steam flow on.

The SOG should continue to be sent to incineration until the back pressure control valve goes closed. At this point steam flow to the stripper can be stopped, and the SOG system (which now contains no pollutants), can be shut down.

In the emergency shutdown situation, such as when the fire goes out at the kiln or incinerator, it is necessary to vent the gases coming off the column. To virtually eliminate this venting, condensate flow to the column should be stopped immediately and at the same time the pressure control valve at the column should be closed. However, steam flow should remain unchanged. This will keep the system in thermal balance, which is especially important if integrated into the evaporator. It will also speed up the restart of the system. As before, on the restart, the condensate flow must be brought on slowly.

CONCLUSION

The Cluster Rule requires collection and treatment of foul condensates to reduce Kraft Pulp Mill pollution. The stripping of foul condensates is a good in-plant method of doing this. BOD, toxicity and odor can be reduced by stripping. In most cases, the pollutants can be converted to a usable fuel, giving an economic return on investment.

BIBLIOGRAPHY

Burgess, T. L. and Voigt, D. Nekoosa Cleans Condensates with Steam Distillation. Pulp and Paper Canada 79 (8): T268-270 (Aug., 1978)

THE BASICS OF FOUL CONDENSATE STRIPPING

TOM BURGESS

**SENIOR MANAGER
ENVIRONMENTAL TECHNOLOGY
GEORGIA-PACIFIC CORPORATION
ATLANTA, GEORGIA**

**Most Kraft Mills Have
Foul Condensate Strippers
in order to reduce
Hazardous Air Pollutants
under the Cluster Rule**

**INPLANT POLLUTION
CONTROL FOR:**

B.O.D.

14 to 20 lb./ton

7 to 10 kg/tonne

**INPLANT POLLUTION
CONTROL FOR:**

**TOXICITY
(Turpenes and Red Oils)**

2 to 4 lb./ton

1 to 2 kg/tonne

**INPLANT POLLUTION
CONTROL FOR:**

**ODOR
TRS**

2 to 4 lb./ton

1 to 2 kg/tonne


OTHER BENEFITS

- **REDUCED MILL WATER USE**
- **REDUCED FOSSIL FUEL USE**

FOUL CONDENSATES FOR STRIPPING

- CONDENSED BLOW STEAM
- CONDENSED RELIEF STEAM
- TURPENTINE UNDERFLOW
- EVAPORATOR COMBINED CONDENSATES
- NCG SYSTEM CONDENSATES

BASIC STRIPPER




BASIC STRIPPER STRIPPER COLUMN


FOR 1000 TPD MILL (300 gpm, 1150l/m)



STRIPPER
COLUMN

- Column 6 ft.(2m) diameter
- Column 60 ft (18m) high
- Operates at 10 psig (170 kPa)
- Uses 20 valve trays
- 5 trays in top section
- 15 trays in bottom section
- 300 series Stainless Steel





BASIC STRIPPER HEAT EXCHANGER

- **Standard is Shell and Tube, with 300 Series Stainless Steel tubes**
- **Clean condensate on tube side, foul on the shell side**
- **Spirals may be better**
- **Plate type plug quickly unless designed for white water service**
- **Must heat condensate to within 20°F (10°C) of column temperature**


BASIC STRIPPER FEED TANK

- **THE BIGGER THE BETTER**
- **30 MINUTE RETENTION TIME
MINIMUM**
- **SEVERAL HOURS BETTER**
- **300 SERIES STAINLESS STEEL**
- **MUST BE VENTED TO
CONCENTRATED NCG**

BASIC STRIPPER REFLUX CONDENSER

- **SHELL AND TUBE HEAT EXCHANGER**
- **ALL 300 SERIES STAINLESS STEEL**
- **MOUNTED HORIZONTALLY OR
VERTICALLY**
- **COOLANT THROUGH TUBES**
- **USES WATER OR WEAK BLACK
LIQUOR FOR COOLING**

BASIC STRIPPER



STEAM REQUIREMENT


- Normally use steam ratio of 0.2 pounds of steam per pound of condensate.
- For 300 gpm (1150 l/m), this is 30,000 lb/hr (13,600 kg/hr) steam
- Require effective steam ratio of 0.16 to 0.18 to get good efficiency

STEAM REQUIREMENT


Some steam is condensed to bring the incoming condensate up to the column operating temperature.

What is left is the
EFFECTIVE STEAM

EFFECTIVE STEAM



STRIPPER EFFICIENCY




COMPLIANCE MONITORING

We must show that the stripper is operating with enough effective steam to ensure adequate methanol removal.


For each stripper, develop a curve for desired efficiency at various steam ratios and delta T.

Operate below the curve.

COMPLIANCE MONITORING



COMPLIANCE MONITORING



INTEGRATED COLUMNS

Advantages

**Lower Capital Cost
Lower Operating Cost**


Disadvantages

**Loss of Evaporator
Efficiency**

INTEGRATED COLUMNS


**For every K Cal lost due
to integration, two or more
K Cal are returned as
usable fuel**

FULLY INTEGRATED COLUMN



PARTIALLY INTEGRATED COLUMN

Evaporator Steam




OPERATING PROBLEMS

- Foaming
- Unstable Operation
- Steam Collapse
- Reflux Control
- Fiber
- Plugged Heat Exchanger
- Turpentine in Storage Tank


REFLUX CONTROL

Simple




REFLUX CONTROL

Better



STRIPPER GAS SYSTEM



LIQUID METHANOL

- **CLUSTER RULE NOW APPROVES**
- **MANY ADVANTAGES**
 - Higher Stripper uptime
 - Store MeOH as a liquid fuel
 - Measure MeOH flow for compliance monitoring

OPERATING PROCEDURES

- **Start up on Steam**
- **Add Condensate Slowly**
- **Make Small Step Changes**

EMERGENCY SHUTDOWN

- **Close Pressure Control Valve**
- **Stop Condensate Flow**
- **Leave Steam On**

CONCLUSION

**STRIPPING IS A GOOD
METHOD OF MEETING
THE CLUSTER RULES**